



Pumptec Diagnostics

Member of the Pumptec Services Group.

CLIENT **Pumptec Engineering Services Ltd**

Bidston House
Old Bidston Road
Birkenhead
Cheshire
CH41 8EL

DATE 21/01/2008

PAGE 1 of 12

ASSEST NO	LOCATION	DESCRIPTION	VISUAL	E BOND	INSUL	ELEAK	STATUS	TESTED
456982	MAIN WORKSHOP	EXTENSION LEAD 240V	PASS	0	20	0	PASS	21/01/2008
456983	MAIN WORKSHOP	EXTENSION LEAD 240V	PASS	0	20	0	PASS	21/01/2008
456984	MAIN WORKSHOP	EXTENSION LEAD 240V	PASS	0	20	0	PASS	21/01/2008
456985	MAIN WORKSHOP	EXTENSION LEAD 240V	PASS	0	20	0	PASS	21/01/2008
456986	MAIN WORKSHOP	EXTENSION LEAD 110V	PASS	0	20	0	PASS	21/01/2008
456987	MAIN WORKSHOP	EXTENSION LEAD 110V	PASS	0	20	0	PASS	21/01/2008
456988	MAIN WORKSHOP	EXTENSION LEAD 110V	PASS	0	20	0	PASS	21/01/2008
456989	MAIN WORKSHOP	EXTENSION LEAD 110V	PASS	0	20	0	PASS	21/01/2008
456990	MAIN WORKSHOP	EXTENSION LEAD 110V	PASS	0	20	0	PASS	21/01/2008
456991	MAIN WORKSHOP	EXTENSION LEAD 110V	PASS	0	20	0	PASS	21/01/2008
456992	MAIN WORKSHOP	GRINDER 1	PASS	0	20	0	PASS	21/01/2008
456993	MAIN WORKSHOP	GRINDER 2	PASS	0	20	0	PASS	21/01/2008
456994	MAIN WORKSHOP	GRINDER 3	PASS	0	20	0	PASS	21/01/2008
456995	MAIN WORKSHOP	GRINDER 4	PASS	0	20	0	PASS	21/01/2008
456996	MAIN WORKSHOP	TRANSFORMER PACK 1	PASS	0	20	0	PASS	21/01/2008
456997	MAIN WORKSHOP	TRANSFORMER PACK 2	PASS	0	20	0	PASS	21/01/2008
456998	MAIN WORKSHOP	TRANSFORMER PACK 3	PASS	0	20	0	PASS	21/01/2008
456999	MAIN WORKSHOP	PORTABLE LAMP 1	PASS	0	20	0	PASS	21/01/2008
457000	MAIN WORKSHOP	PORTABLE LAMP 2	PASS	0	20	0	PASS	21/01/2008
457001	MAIN WORKSHOP	PORTABLE DRILL CHARGER	PASS	0	20	0	PASS	21/01/2008
457002	MAIN WORKSHOP	PORTABLE PHONE CHARGER 1	PASS	0	20	0	PASS	21/01/2008
457003	MAIN WORKSHOP	PORTABLE PHONE CHARGER 2	PASS	0	20	0	PASS	21/01/2008
457004	MAIN WORKSHOP	SMALL PORTABLE FAN 9	PASS	0	20	0	PASS	21/01/2008
457005	MAIN OFFICE	PC 1	PASS	0	20	0	PASS	21/01/2008
457006	MAIN OFFICE	PC 2	PASS	0	20	0	PASS	21/01/2008
457007	MAIN OFFICE	PC 3	PASS	0	20	0	PASS	21/01/2008
457008	MAIN OFFICE	PC 4	PASS	0	20	0	PASS	21/01/2008
457009	MAIN OFFICE	PC 5	PASS	0	20	0	PASS	21/01/2008
457010	MAIN OFFICE	PC 6	PASS	0	20	0	PASS	21/01/2008
457011	MAIN OFFICE	PC 7	PASS	0	20	0	PASS	21/01/2008
457012	MAIN OFFICE	LAPTOP 1	PASS	0	20	0	PASS	21/01/2008
457013	MAIN OFFICE	LAPTOP 2	PASS	0	20	0	PASS	21/01/2008
457014	MAIN OFFICE	LAPTOP 3	PASS	0	20	0	PASS	21/01/2008
457015	MAIN OFFICE	LAPTOP 4	PASS	0	20	0	PASS	21/01/2008
457016	MAIN OFFICE	LAPTOP 5	PASS	0	20	0	PASS	21/01/2008
457017	MAIN OFFICE	PRINTER A3	PASS	0	20	0	PASS	21/01/2008
457018	MAIN OFFICE	PRINTER A3 LASER	PASS	0	20	0	PASS	21/01/2008
457019	MAIN OFFICE	PRINTER A4 COLOUR LASER 1	PASS	0	20	0	PASS	21/01/2008
457020	MAIN OFFICE	PRINTER A4 COLOUR LASER 2	PASS	0	20	0	PASS	21/01/2008
457021	MAIN OFFICE	MONO PRINTER	PASS	0	20	0	PASS	21/01/2008
457022	MAIN OFFICE	EXTENSION LEAD	PASS	0	20	0	PASS	21/01/2008
457023	MAIN OFFICE	HEATER	PASS	0	20	0	PASS	21/01/2008
457024	MAIN OFFICE	FAN 1	PASS	0	20	0	PASS	21/01/2008
457025	MAIN OFFICE	FAN 2	PASS	0	20	0	PASS	21/01/2008
457026	MAIN OFFICE	FAN 3	PASS	0	20	0	PASS	21/01/2008
457027	MAIN OFFICE	LAMINATOR (SMALL)	PASS	0	20	0	PASS	21/01/2008
457028	MAIN OFFICE	LAMINATOR	PASS	0	20	0	PASS	21/01/2008
457029	MAIN OFFICE	LCD MONITOR 1	PASS	0	20	0	PASS	21/01/2008

Tested by:

(Print)

(Sign)

(Date)